




HEPA CRANK SEAL QUOTE/SUBMITTAL

Date _____ Customer: _____ Quote No. _____

- Gasket Seal
- Fluid Seal



Door Location

- Two Doors (standard)
- Right Hand
- Left Hand

Material

- Galvanized 14 GA
- Aluminized Steel 14 GA
- 304L Stainless Steel
- 316L Stainless Steel

Size

(check height and width box)

Height

- 1 H 27 1/4"
- 2 H 51 3/4"
- 3 H 76 1/4"

Dimension

Width

- 1 W 24 1/8"
- 2 W 48 1/8"
- 3 W 72 1/8"

Dimension

Other Size

N/A N/A N/A N/A

Depth

- 21 1/2" -No Pre-Filter
- 25" -2" Pre-Filter
- 27" -4" Pre-Filter

Special Size

Height _____ Width _____ Depth _____

Options

- Seal Weld
- Insulation
- Nameplate (engraved)
- Vertical Flow
- Drilled Flanges
- 2 Lifting Lugs
- 4 Lifting Lugs
- Magnehelic Gauge
- Model # _____ Installed
- Photohelic Gauge
- Model # _____ Installed
- 1 DOP Port
- 2 DOP Ports
- Double Wall Insulation
- Weather Cover
- Bottom Access
- Transitions
- 2 Static Taps
- 4 Static Taps
- High Temperature Door Gasket
- Magnehelic Gauge
- Model # _____ Uninstalled
- Photohelic Gauge
- Model # _____ Uninstalled
- Nema4 Cover
- Leak Test

Other _____