

4

3

2

1

1 3/4" FLANGES (UPSTREAM AND DOWNSTREAM)

"W"

HEPA FILTER

2 1/2"

HEPA SIDE ACCESS HOUSING FLUID SEAL WITHOUT PREFILTER SPECIFICATION

1. THE HOUSING SHALL BE CONSTRUCTED OF 14 GA GALVANIZED FOR STRUCTURAL REINFORCEMENT, ALL JOINT SHALL BE INTERMITTENTLY OR SEALED WELDED AND SHALL BE FREE OF ALL BURES AND SHARP EDGES. JOINTS SHALL BE SEALED AIRTIGHT WITH SILASTIC CAULKING.
2. THE ACCESS DDDR SHALL HAVE A 1/2" THICK CLOSED-CELL NEOPRENE GASKET AROUND THE INSIDE PERIMETER. STUD AND STAR KNOBS SHALL BE USED TO SECURE THE DDDR.
3. THE STANDARD HOUSING COME WITH A ACCESS DDDR ONE SIDE. STANDARD HOUSING IS A RIGHT HAND ACCESS. THE BUYER MUST SPECIFY LEFT HAND IF REQ'D
4. HOUSING MORE THAN 3 WIDE CONSISTS OF TWO SIDE-BY-SIDE HOUSING IN PARALLEL FILTER REMOVE IS FROM BOTH SIDE OF HOUSING



AIR FLOW

STAR KNOB

LOOKING TRAY

UPSTREAM FLANGES

FRONT VIEW



HEPA FILTER DIMENSION: 24" X 24" X 11 1/2" FOR OTHER SIZES PLEASE CONTACT FACTORY

HOUSING CONFIGURATION	HEIGHT "H"	WIDTH "W"
1 x 1	24 1/8"	24 1/8"
1 x 2	48 1/8"	48 1/8"
1 x 3	72 1/8"	72 1/8"
2 x 1	24 1/8"	24 1/8"
2 x 2	48 1/8"	48 1/8"
2 x 3	72 1/8"	72 1/8"
3 x 1	24 1/8"	24 1/8"
3 x 2	48 1/8"	48 1/8"
3 x 3	72 1/8"	72 1/8"

HOUSING CONFIGURATION _____ X _____

HOUSING DIM: (H) _____ (W) _____ (D) _____

HOUSINGS REQUIRED: _____

A

B

C

D

E

A

B

C

D

E

UNLESS OTHERWISE SPECIFIED
 *TOLERANCES: DO NOT SCALE
 XXX ± .015 Y/X ± 1/16
 XX ± .03 Z ± .5"

THESE DIMENSIONS AND DESCRIPTIONS ARE APPROXIMATE. THE BUYER SHALL VERIFY ALL DIMENSIONS AND REQUIREMENTS BEFORE ORDERING. THE BUYER SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS. THE BUYER SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND APPROVALS.

FILTRATION GROUP
 912 E Washington St.
 Joliet, IL 60433
 Ph (815) 726-4600
 Fax (815) 726-6912

TITLE: HEPA SIDE ACCESS
 PART NO.: _____
 DRAWING NO.: _____

DATE: _____
 BY: _____
 CHECKED: _____
 SCALE: _____

REV: _____
 E.O. DATE: _____
 USED ON: _____
 QTY: _____

RELEASE E.O. SHEET

4

3

2

1

COMPUTER GENERATED DO NOT REVISE MANUALLY